

ADDENDUM 001 Request for Bid Materials for Building RFB 9-160121KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **January 21, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed:01/19/2016

****THIS BID IS FOR MATERIALS ONLY TO INCLUDE DELIVERY.**

Bids must be submitted in a sealed envelope as outlined in Section 1.1 Introduction and Section 3 Bid Submission. E-mails or faxes will not be accepted.

All items within a group **MUST** be priced.

Questions:

Question: Item G4.1 – 4/O Entrance Cable (feet); is this to a single conductor or a cable with multiple conductors? If cable, how many conductors are required?
Also, copper or aluminum?

Answer: Entrance cable 3 wire aluminum.



Question: Items G4.17 (hole clamps – 1 inch for ½ inch EMT) & G4.18 (hole clamps – 1 inch for ¾ inch EMT) Are these to be 1-hole clamps for the different sizes of conduit?

Answer: Yes, one-hole clamps for the different sizes of conduit.

Question: Adapters are listed for the different conduit sizes, do you need couplings as well?

Answer: We will purchase couplings on an as needed basis.